

North Eastern Regional Power Committee

AGENDA OF 18th Metering Committee meeting

Date : 12/07/2016 (Tuesday)
Time : 14:00 hrs
Venue : "Hotel Nandan", Guwahati.

1. Repair/rectification of large time drifted L&T SEMs:

In the last meeting, NERTS representative intimated that since sufficient meters were not available for sending to L&T works, same were not sent. Total 05 nos. of meters were available for sending. Metering Committee felt that such small number should not be sent. After receipt of 06 nos of drifted meters from Doyang, these should also be included for sending to L&T. In addition, NERLDC has given a list of defective meters to NERTS which can also be removed and sent to L&T without affecting accounting. All these meters should be combined and sent to L&T for repair.

NERTS may intimate status.

2. Procurement of 100 USB cords :

In the last meeting, NERTS representative intimated that tender evaluation was in progress and LOA would be placed by 15.06.2016.

NERTS may intimate status.

3. Procurement of additional 70 Laptops:

In last meeting, NERTS representative intimated that demo by two bidders viz M/S EDMI and M/S L&T was complete. Demo by M/S Secure Meters would be completed by end of June'16. Decision regarding procurement of laptop would be taken after that.

NERTS may intimate status.

4. Procurement of 250 SEMs & 60 Laptops/DCDs:

Status as per last meeting:

Field demo by M/S EDMI: 26.04.2016

Field demo by M/S L&T: 30.05.2016

Field demo by M/S Secure: End June 2016

LOA by 15.07.2016

NERTS may intimate status.

5. Installation, operation and maintenance of SEMs and accessories:

The names & contact numbers of meters coordinators are as below:

SL No.	Organization	Name & Designation	Contact Details
1	Ar. Pradesh	Nangkong Perme, EE, SLDC	09436288643
2	Assam	J. K. Baishya, AGM, SLDC	09435041494
3	Manipur	N. Romeo Singh, Dy Mgr, SLDC	09612657280
4	Meghalaya	T. Gidon, EE, SLDC	09774479956
5	Mizoram	Vanlalrema, SE, SLDC	09436140353
6	Nagaland	A. Jakhalu, EE (Trans)	09436002996
7	Tripura	D. Pal, Sr. Mgr	09436500244
8	NEEPCO	B. Majumdar, DM, RHEP	09612079362
		Sudip Das, DM, Kopili HEP	09401237613
		Ashim Sharma, DM, Khandong HEP	09435078860
		Bendang, Mgr. Doyang HEP	09862769848
		D. Goswami, Sr. Mgr. AGBPP	09435577655
		Prasenjit Sen, Sr. Mgr, AGTPP	09436167999
9	NHPC (Loktak)	Md. Sajid Akhtar, Mgr	09436678603
10	OTPC (Palatana)	N. Gupta, Mgr	09774233426
11	NTPC (Bongaigaon)	J. Bhattacharya, AGM	09435720036
12	NERLDC	Babul Roy, Mgr	09436335377
13	NERTS, PGCIL	Supriyo Paul, Mgr	09436302995
		S.K. Singh, Mgr	09435706099
		Ravi Sarma, Sr. Engr.	09435560889

The nodal officers were advised to submit the DCD status report at the earliest before next metering committee meeting. Report may be submitted by e-mail to NERPC/NERLDC.

NERTS representative intimated following:

Status of DCD with POWERGRID:

Total DCDs available at S/S : 50

DCDs in working condition: 23

DCDs lying defective: 24

New DCD in store: 03

DCDs sent for repair: 19

Others (except Meghalaya) may furnish status.

6. Time Drift in Meters & action required:

Status as per last meeting:

1. Replace sem NP-5796-A at Samaguri end of Misa-2: **To be done on 11.06.16**
2. Replace sem NP-7594-A at Panchgram end of Silchar: **To be done on 12.06.16**
3. Replace sem NP-6034-A at Gohpur end of Nirjuli: **To be done on 12.06.16**

NERLDC requested all concerned to regularly check meter time in SEM and provide time correction command as and when required to avoid large time drift.

NERTS may update.

Testing of SEMs: On an enquiry from OTPC, it was clarified that there is no provision of calibration of meters. As per CEA metering regulations, meters are to be tested at accredited lab every five meters. NERTS intimated that such testing would be planned after receipt of 250 SEMs being procured. NERTS-NERLDC would prepare a list of SEMs with date of installation/supply which would help in the activity.

In last meeting it was decided that NERTS would provide the inputs being procurement, installation agency and along with NERLDC should prepare the list based on records.

NERTS may intimate status.

Time drift of KHEP SEMs: NERTS representative intimated in the last meeting that that Misa representative would visit Kopili on 10.06.2016.

NERTS and NEEPCO may intimate status.

7. AMR scheme in NER.

In the last meeting, NERLDC had stated that comments had been submitted on draft TS. It was agreed that NERTS would proceed with the scheme accordingly.

NERTS may intimate status.

8. Replacement of SEMs at Doyang

NERTS may intimate status.

9. SEMs at NTPC, BgTPP

In the last meeting, it was decided that one USB-Optical cable would be provided to NTPC by NERTS and requisite software would also be loaded in laptop. NTPC would download reading from two newly installed SEMs and mail to NERLDC.

NERTS and NTPC may intimate status.

10. Metering issues:

Meter reading at Mendipathar: It was noted in the last meeting that DCD was handed over to Mendipathar by NERTS. However, due to non-availability of requisite software, Mendipathar was not able to download and transmit data. NERTS agreed to provide software to them.

NERTS may intimate status.

Non-receipt of Umrangsoo meter readings: NERLDC requested AEGCL to send reading of SEMs installed at Umrangsoo against 132 Khandong-Umrangsoo and 132 Umrangsoo-Haflong feeders. AEGCL representative agreed to do the needful.

AEGCL may intimate status.

Date and venue of next meeting
