

## North Eastern Regional Power Committee

### **AGENDA OF 19<sup>th</sup> Metering Committee meeting**

**Date** : 08/08/2016 (Monday)

**Time** : 14:00 hrs

**Venue** : "Pala Resort", Cherrapunjee.

#### **1. Repair/rectification of large time drifted L&T SEMs:**

The following meters were to be sent for repair:--

- i) 16 Nos. as per list of NERLDC.
- ii) 5 nos. already available in NERTS
- iii) 4 Nos., defective from Doyang.
- iv) 4 nos. Time drifted old Meters of Doyang

**NERTS may intimate status of sending the meters to L&T works.**

#### **2. Procurement of 100 USB cords:**

Status as per 18<sup>th</sup> Metering Meeting:

LOA Placement to L&T: on 12-07-2016 Supply by: 15-08-2016

**NERTS may intimate status.**

#### **3. Procurement of additional 70 Laptops:**

In the last meeting, it was informed that M/s Secure Meters Ltd. reported at Shillong on 11-07-2016. Demo would be completed by 12-07-2016. Decision would be taken accordingly after recommendation of the committee constituted for the above demo.

**NERTS may intimate status.**

#### **4. Procurement of 250 SEMs & 60 Laptops/DCDs:**

In the last meeting, NERTS intimated that Demo by M/s Secure Ltd would be completed by 12-07-2016.

Tentative Date for LOA : 15-08-2016

**NERTS may intimate status.**

**5. Installation, operation and maintenance of SEMs and accessories:**

The names & contact numbers of meters coordinators are as below:

SL No.	Organization	Name & Designation	Contact Details
1	Ar. Pradesh	Nangkong Perme, EE, SLDC	09436288643
2	Assam	J. K. Baishya, AGM, SLDC	09435041494
3	Manipur	N. Romeo Singh, Dy Mgr, SLDC	09612657280
4	Meghalaya	T. Gidon, EE, SLDC	09774479956
5	Mizoram	Vanlalrema, SE, SLDC	09436140353
6	Nagaland	A. Jakhalu, EE (Trans)	09436002996
7	Tripura	D. Pal, Sr. Mgr	09436500244
8	NEEPCO	B. Majumdar, DM, RHEP	09612079362
		Sudip Das, DM, Kopili HEP	09401237613
		Ashim Sharma, DM, Khandong HEP	09435078860
		Bendang, Mgr. Doyang HEP	09862769848
		D. Goswami, Sr. Mgr. AGBPP	09435577655
		Prasenjit Sen, Sr. Mgr, AGTPP	09436167999
9	NHPC (Loktak)	Md. Sajid Akhtar, Mgr	09436678603
10	OTPC (Palatana)	N. Gupta, Mgr	09774233426
11	NTPC (Bongaigaon)	J. Bhattacharya, AGM	09435720036
12	NERLDC	Babul Roy, Mgr	09436335377
13	NERTS, PGCIL	Supriyo Paul, Mgr	09436302995
		S.K. Singh, Mgr	09435706099
		Ravi Sarma, Sr. Engr.	09435560889

*The nodal officers were advised to submit the DCD status report at the earliest before next metering committee meeting. Report may be submitted by e-mail to NERPC/NERLDC.*

NERTS representative intimated following:

Status of DCD with POWERGRID:

Total DCDs available at S/S : 50  
 DCDs in working condition: 23  
 DCDs lying defective: 24  
 New DCD in store: 03  
 DCDs sent for repair: 19

In the last meeting, NERTS informed that DCDs sent for repair are under repairing stage.

**Others (except Meghalaya) may furnish status.**

**6. Time Drift in Meters & action required:-**

NERLDC stressed the importance of providing regular time correction command in SEMs to avoid large drift.

**All concerned are requested to provide action taken status.**

**Testing of SEMs:** NERTS-NERLDC would prepare a list of SEMs with date of installation/supply which would help in the activity.

NERTS informed that List of installed SEM was being prepared by POWERGRID.

**NERTS may intimate status.**

**Time drift of KHEP SEMs:**

NERTS representative planned to visit on 14<sup>th</sup> July-2016 for drift correction as time drift of the order of 1 minute is reported in 5 meters and of the order of 5 minutes in one meter.

**NERTS may intimate status.**

**7. AMR scheme in NER.**

NERTS informed that they were going ahead with the above TS with minor modification to be provided by NERLDC.

**NERTS may intimate status.**

**8. Replacement of SEMs at Doyang**

NERTS informed that for replacement of the 8 nos. of time Drifted meters at Doyang end, POWERGRID representative reached Doyang on 28-06-2016 , However out of 8 Nos. of time drifted Meters only 4(four) SEM could be replaced as follows. Balance 4 nos. could not be replaced as 4 nos. of new meters taken for replacement were defective.

List of Meters Replaced at Doyang end:

- i. 132kV Doyang-Dimapur -I
- ii. 132kV Doyang-Dimapur-II
- iii. 132kV Doyang – Mokokchung
- iv. 5 MVA 132/33kV SST

Balance planned to be replaced on availability of healthy SEM.

**New SEM would be needed in Doyang end of Doyang-Wokha line.**

**NERTS may intimate status.**

**9. Metering issues:**

**Non-receipt of Umrangsoo meter readings:** NERLDC requested AEGCL to send reading of SEMs installed at Umrangsoo against 132 Khandong-Umrangsoo and 132 Umrangsoo-Haflong feeders. AEGCL representative agreed to do the needful.

**AEGCL may intimate status.**