

North Eastern Regional Power Committee

AGENDA OF 20th Metering Committee meeting

Date : 14/09/2016 (Wednesday)

Time : 14:00 hrs

Venue : "Hotel Nandan", Guwahati.

1. Repair/rectification of large time drifted L&T SEMs:

Status as per last meeting:

NERTS stated that a total of 11(Eleven) Nos. of SEM meters had already been sent to L&T Works on 02.08.2016.

i) Out of the list of 16, only 06(six) meters could be sent to L&T, status for balance 10 is as follows:--

a) NP 8372A: POWERGRID visited site but Naharlagun denied handing over to POWERGRID. **AP was advised to hand over the SEM during next visit of NERTS.**

b) NP 6154A & NP 5781A: POWERGRID visited site but NEEPCO denied handing over to POWERGRID. **NEEPCO was advised to hand over the SEM during next visit of NERTS.**

c) NP 5301A: Planned sending from Misa to L&T on 10-08-2016

d) Balance 2 Nos. of Palatana planned sending from Misa on 10-08-2016

e) NP 5304A/NP 5305A planned sending from Misa on 10-08-2016

f) NP 8487A: POWERGRID few months back visited site but Nangalbibra official denied to hand over to POWERGRID. **Meghalaya was advised to hand over the SEM during next visit of NERTS.**

ii) SEM already available at Misa is planned for sending on 14-08-2016.

iii) 4 Nos. defective from Doyang: SEM at Misa end. Planned for sending on 14-08-2016.

iv) 4 Nos. Time drifted Meters received from Doyang already sent to L&T works on 02.08.2016.

NERTS may intimate the current status

2. Procurement of 100 USB cords :

Status as per last meeting:

LOA Date: 03.08.2016, Supply by: 15-09-2016

NERTS may intimate the current status

3. Procurement of additional 70 Laptops:

Status as per last meeting:

Field Demonstration already completed. Further, committee reports have been finalized.

Accordingly, decision has been taken for procurement of 70 nos. of Laptops by IT Department, POWERGRID, Shillong.

Date of Finalization of Proposal: 09.08.2016

Tentative Date of Tender: 25-08-2016

Tentative Date of Bid Opening: - 25-09-2016

Tentative Date of LOA: 25-10-2016

Tentative Date of Supply: 25-12-2016

NERTS may intimate the current status

4. Procurement of 250 SEMs & 60 Laptops/DCDs:

Status as per last meeting:

Field Demonstration already completed on 12-07-2016. Further, committee report has been finalized.

Tentative Date for NOA/LOA: 31-08-2016

NERTS may intimate the current status

5. Installation, operation and maintenance of SEMs and accessories:

The names & contact numbers of meters coordinators are as below:

SL No.	Organization	Name & Designation	Contact Details
1	Ar. Pradesh	Nangkong Perme, EE, SLDC	09436288643
2	Assam	J. K. Baishya, AGM, SLDC	09435041494
3	Manipur	N. Romeo Singh, Dy Mgr, SLDC	09612657280
4	Meghalaya	T. Gidon, EE, SLDC	09774479956
5	Mizoram	Vanlalrema, SE, SLDC	09436140353
6	Nagaland	A. Jakhalu, EE (Trans)	09436002996
7	Tripura	D. Pal, Sr. Mgr	09436500244
8	NEEPCO	B. Majumdar, DM, RHEP	09612079362
		Sudip Das, DM, Kopili HEP	09401237613
		Ashim Sharma, DM, Khandong HEP	09435078860
		Bendang, Mgr. Doyang HEP	09862769848

		D. Goswami, Sr. Mgr. AGBPP	09435577655
		Prasenjit Sen, Sr. Mgr, AGTPP	09436167999
9	NHPC (Loktak)	Md. Sajid Akhtar, Mgr	09436678603
10	OTPC (Palatana)	N. Gupta, Mgr	09774233426
11	NTPC (Bongaigaon)	J. Bhattacharya, AGM	09435720036
12	NERLDC	Babul Roy, Mgr	09436335377
13	NERTS, PGCIL	Supriyo Paul, Mgr	09436302995
		S.K. Singh, Mgr	09435706099
		Ravi Sarma, Sr. Engr.	09435560889

The nodal officers were advised to submit the DCD status report at the earliest before next metering committee meeting. Report may be submitted by e-mail to NERPC/NERLDC.

Status of DCD with POWERGRID:

Total DCDs available at S/S : 50
 DCDs in working condition: 23
 DCDs lying defective: 24
 New DCD in store: 03
 DCDs sent for repair: 19

Status furnished by NERTS in last meeting:

The party will give confirmation about readiness of the DCD already sent for repair by 09.08.2016. The party is yet to confirm about whether repair for balance DCD will be at same rate /terms and conditions. However, next lot of DCD will be sent to factory by 16.08.2016 for checking & reparability condition checks.

Members may like to discuss.

6. Time Drift in Meters & action required:-

NERLDC stressed the importance of providing regular time correction command in SEMs to avoid large drift.

All concerned agreed to do the needful and furnish fresh report. NERLDC pointed out that large time drift in Meter No. NP-5287(DIMAPUR END OF 132kV BOKAJAN FDR) may be corrected at the earliest.

Members may like to discuss.

Testing of SEMs: NERTS-NERLDC would prepare a list of SEMs with date of installation/supply which would help in the activity.

NERTS informed that List of installed SEM was being prepared by POWERGRID.

NERTS may intimate status.

7. AMR scheme in NER.

NERTS informed that the Final TS would be submitted to their Contacts Deptt. by 10-08-2016 for necessary e-tendering. NERLDC may provide input if required.

NERTS may intimate status.

8. Replacement of SEMs at Doyang

NERTS stated the following in last meeting:

4 Nos. of SEM pending for replacement can be taken up only after receipt of SEM sent for time drift correction.

Further, as per NERLDC E-mail Dated 26-07-2016, one SEM No. NP 8799A, taken out from Misa end of Kathalguri Feeder and handed over to Dimapur POWERGRID official on 06-08-2016. The SEM meter is planned for replacement on 08.08.2016.

Members may like to discuss.

9. Metering issues:

Non-receipt of Umrangsoo meter readings: NERLDC requested AEGCL to send reading of SEMs installed at Umrangsoo against 132 Khandong-Umrangsoo and 132 Umrangsoo-Haflong feeders. AEGCL representative agreed to do the needful. AEGCL representative agreed to send the SEMs data of Umrangsoo Substation.

Members may like to discuss.

Any Additional Items:

Date and venue of next meeting
