

## North Eastern Regional Power Committee

### **AGENDA OF 22<sup>nd</sup>. Metering Committee meeting**

Date : 14/12/2016 (Wednesday)

Time : 14:00 hrs

Venue : "Hotel Nandan", Guwahati.

#### **1. Repair/rectification of large time drifted L&T SEMs:**

Status as per last meeting:

NERTS intimated that M/s L&T had corrected 10 Nos. SEM which would be ready for dispatch. However , there was some contractual issues which is now clear. POWERGRID will release payment (advance) for dispatch of the SEMs. Tentative receipt date is 30-11-2016.

The 3<sup>rd</sup> LOT of SEM Meters (**28 Nos.**) were sent for repair/correction during September end and the meters were received by L&T . The party intimated that the SEMs will be ready for dispatch within 10-15 days time i.e. by 30-11-2016

**NERTS may confirm receipt of 10 SEMs and deployment in locations as decided in last Metering Meeting and as advised by NERLDC.**

#### **2. Procurement of 100 USB cords:**

Status as per last meeting:

NERTS intimated that The USB cables (50 + 50 Nos.) had been dispatched by M/s L&T on **11-11-2016** to Shillong as well as Misa Substation.

**NERTS may confirm receipt of USB cables and deployment in locations as decided in last Metering Meeting and as advised by NERLDC.**

#### **3. Procurement of additional 70 Laptops:**

Status as per last meeting:

Tender Floated : 05.11.2016

Date of Bid Opening : 15.12.2016

Tentative Date of LOA : 31.12.2016

Tentative Date of Supply : 15.02.2017.

**NERTS may update**

**4. Procurement of 250 SEMs & 60 Laptops/DCDs:**

Status as per last meeting:

Date of Placement of LOA/NOA: 07-10-2016.

Delivery (Tentative) : Mid of January-2017

**Metering Committee may note**

**5. Installation, operation and maintenance of SEMs and accessories:**

Status as per last meeting:

Repaired DCD received at Misa Substation:- 22 Nos.

DCD presently under repair :- 26 Nos.

**NERTS may confirm deployment of DCDs in locations as decided in last Metering Meeting and as advised by NERLDC.**

**6. Time Drift in Meters & action required:-**

NERLDC stressed the importance of providing regular time correction command in SEMs to avoid large drift.

NERTS intimated that since the time drift in Bokajan Feeder at Dimapur PG end is very high(27 minutes) which takes 6 months from date of correction as such replacement of the SEM is planned on receipt of time drift corrected SEM from L&T.

**Testing of SEMs:** NERTS-NERLDC would prepare a list of SEMs with date of installation/supply which would help in the activity.

NERTS informed that List of installed SEM was being prepared by POWERGRID.

***NERTS and utilities may intimate status on both points.***

**7. AMR scheme in NER.**

Status as per last meeting:

NERTS intimated that the Technical Specification has already been approved. The QR has been prepared and under approval stage.

Documents for Open Tendering for the above will be ready by end of November-2016.

***NERTS may intimate status.***

#### **8. Replacement of SEMs at Doyang**

NERTS stated the following in last meeting:

The time corrected SEM will be received tentatively by end of November-2016. Accordingly the SEM will be replaced at Doyang Substation by 07-12-2016.

***NERTS may intimate status.***

#### **9. Metering issues:**

##### **Non-receipt of Umrangsoo meter readings:**

AEGCL requested for a DCD in Umrangsoo. NERTS was advised to hand over a DCD to Umrangsoo.

***NERTS may intimate status.***

##### **Non-receipt of Meter data from following locations –**

Tinsukia(Assam)

**AEGCL may intimate status.**

Sonabil (Assam)

AEGCL requested to hand over a DCD to Sonabil. NERTS was advised accordingly.

***NERTS may intimate status.***

- Shifting of Gohpur end SEM of 132 kV Balipara-Gohpur to Sonabil end (Balipara-Gohpur LILoed at Sonabil)

***NERTS/AEGCL may intimate status.***

- Shifting of Dullavchera end SEM of 132 kV Silchar-Dullarchera to Hailakandi.

NERTS/AEGCL agreed to furnish installation report on shifting of Meter to Hailakandi.

***NERTS/AEGCL may intimate status.***

- Replacement of 2 SEMs ( 5808 & 5317) AT NTPC-BgTPP

It was decided that two SEMs will be replaced in NTPC in first week of Dec'16 after receipt of rectified meters from L&T works.

***NERTS may intimate status.***

- Handing over DCDs to various locations (consolidated list)

It was decided to hand over DCDs by NERTS to following locations for which advice would be sent by NERLDC to NERTS

Killing, Meghalaya

Umtru, Meghalaya

Lumshnong, Meghalaya

Hailakandi, Assam

Sonabil, Assam

Umrangsoo, Assam

NTPC, Bongaigaon

***NERTS may intimate status.***

**Date and venue of next meeting**

\*\*\*\*\*