

North Eastern Regional Power Committee

AGENDA OF 12th. Metering Committee meeting

Date : 08/01/2016 (Friday)
Time : 14:00 hrs
Venue : "Hotel Nandan", Guwahati.

1. Repair/rectification of large time drifted L&T SEMs:

(a) The Sub-committee in 11th. Meeting decided that first lot of around 25 SEMs will be sent for repairing immediately and NERTS will depute suitable officer for handing these meters personally to the factory and at the same time the forum requested M/s L&T representative to take proactive action with their manufacturing plant to help in repair these meters at the shortest possible time.

(b) It was also decided that NERTS will purchase 10 nos. of Optical to USB cord from M/S L&T immediately and collect while repairing SEMs at L&T works. These will be given to priority locations for direct data download from SEM to Laptop. Subsequently, around 50 nos. cords will be procured for giving to all locations.

(c) EE, SLDC MePTCL informed that DCDs at Umtru, Killing & Nangabibra are not working. He requested NERTS to spare one DCD so that reading can be taken.

NERTS agreed and the same will be handed over to MePTCL soon.

NERTS may intimate status.

2. Procurement of 250 SEMs/60 Laptops:

As per POWERGRID-NERTS, schedule for procurement (250 meters) are as under:

Floating of NIT	:	02.11.2015
Opening of Bid Document	:	1st week of January, 2016
Issue of LOA	:	2 nd week of February, 2016

The Sub-committee requested NERTS to modify the NIT since the forum decided that 20 DCDs are no longer required and instead 20 Laptops should be procured in place of DCDs.

NERTS may intimate status.

3. Installation, operation and maintenance of SEMs and accessories:

Co-ordinators were decided as below:

SL No.	Organization	Name & Designation	Contact Details
1	Ar. Pradesh	Nangkong Perme, EE, SLDC	09436288643
2	Assam	J. K. Baishya, AGM, SLDC	09435041494
3	Manipur	N. Romeo Singh, Dy Mgr, SLDC	09612657280
4	Meghalaya	T. Gidon, EE, SLDC	09774479956
5	Mizoram	Vanlalrema, SE, SLDC	09436140353
6	Nagaland	A. Jakhalu, EE (Trans)	09436002996
7	Tripura	D. Pal, Sr. Mgr	09436500244
8	NEEPCO	B. Majumdar, DM, RHEP	09612079362
		Sudip Das, DM, Kopili HEP	09401237613
		Ashim Sharma, DM, Khandong HEP	09435078860
		Bendang, Mgr. Doyang HEP	09862769848
		D. Goswami, Sr. Mgr. AGBPP	09435577655
		Prasenjit Sen, Sr. Mgr, AGTPP	09436167999
9	NHPC (Loktak)	Md. Sajid Akhtar, Mgr	09436678603
10	OTPC (Palatana)	N. Gupta, Mgr	09774233426
11	NTPC (Bongaigaon)	J. Bhattacharya, AGM	09435720036
12	NERLDC	Babul Roy, Mgr	09436335377
13	NERTS, PGCIL	Supriyo Pal, Mgr	09436302995

It was decided that the above officers will be contacted for any metering issues and necessary action is to be taken by them.

Metering co-coordinators may furnish any point for deliberation.

4. Time Drift in Meters & action required:

Time correction option through DCD (L&T) one minute at a time as decided in 11th meeting is as below:

Simple three step process.

1. Press "P" in DCD
2. Enter password "XMISSION"
3. Press "A" or "R" for time advance / retard

After this, SEM should be kept powered ON for 90 minutes.

No further correction possible in next 7 days.

(a) As decided earlier, NERTS was requested to furnish time drift status report of locations of States also by 31.12.2015. This would enable getting a complete picture and plan can be chalked out to replace large drifted SEMs.

(b) The forum requested M/s L&T to give the offer regarding exchanging the old meters with new meters so that further necessary action can be taken up.

NERTS may intimate status on the above points.

5. AMR scheme in NER.

As per NERTS, current status is as below:

Floating of NIT : 15.01.2016

Opening of Bid Document : 16.02.2016

NERTS may intimate status.

6. Collection of SEM reading at Bokajan

DGM (AM) informed that NERTS is helping to carry out the data downloading for Dimapur – Bokajan link. He requested that on providing DCD, State should carry out the activity.

Metering Committee may discuss

7. Metering issues:

1. 132 KV Badarpur-Kolasib – Error in Kolasib end reading persisting. -
2. 132 KV Palatana-Udaipur – Udaipur reading continues to be 2/3rd.
3. Non receipt of reading from Nangalbibra, Deomali, Rengpang
4. Pavo end meter of BNC 132 KV line-2 showing no. **NA-4495-A**
5. Error in Bongaigaon end SEM of 400 KV Binaguri-Bongaigaon –III - yet to be resolved.

Metering Committee may discuss

8. Time drift in OTPC SEMs, providing Laptops in Power Station Control rooms

As per report submitted by OTPC, four SEMs connected at GTG-1(7585), STG-1(7582), STG-2(6928) and ST-1(7602) are drifted by 11-12 minutes. These are standby meters and are not used for accounting. However, on receipt of rectified SEMs from L&T, these will be replaced.

Metering Committee may discuss and OTPC may be advised to apply time correction command to other SEMs which are drifted by 2-4 minutes.

9. Date and Venue of next MM

It is proposed to hold the 13th Metering meeting of NERPC on second week of February, 2016. The date & exact venue will be intimated in due course.
