

## North Eastern Regional Power Committee

### **AGENDA OF 32<sup>nd</sup> Metering Committee meeting**

Date : 27/10/2017 (Friday)  
Time : 14:00 hrs  
Venue : "Hotel Nandan"Guwahati.

#### **1. Repair/rectification of L&T SEMs:**

Status as per last meeting regarding installation of **SEM at Sanis:**

Dimapur team visited no of times, however due to extremely bad road conditions could not reach Sanis site for installation of the Meter. The meter would be installed immediately after road opens for vehicle movement.

Subsequently NERTS has installed SEM at Sanis on 22.09.17.

But reading is not being received.

**Nagaland to take action.**

#### **2. Procurement of additional 70 Laptops:**

Status as per last meeting intimated by NERTS:

Communication was sent to the vendors to accept the reduced base rate after exclusion of ED and CST from the quoted rates. The reduced base rate was due to the incorporation of GST. On confirmation of the base rate, e-RA would be carried out . Following is the revised schedule:-

- i. e-RA : 22.09.2017
- ii. LOA :07.10.2017
- iii. Material Dispatch : 31.10.2017

**NERTS may intimate status.**

#### **3. Procurement of 250 SEMs & 60 Laptops/DCDs:**

##### **3 (a) Distribution of Laptops:**

NERLDC intimated that a LAPTOP had been issued to TSECL but same was not being used for collection of SEM data.

TSECL representative intimated that VINPLUS software in the Laptop was not functioning properly and they were not able to download reading. Subsequently TSECL was advised to hand over the Laptop to Agartala PG for rectification.

**TSECL/NERTS may intimate status.**

**3 (b) Installation of new L&T SEMs in NER:**

The detailed SEM Installation schedule was submitted by NERTS and requested availability of concerned Engineers of respective utilities for installation activity. The schedule was agreed by Metering Committee.

**NERTS may intimate status of installation so far.**

NERTS further submitted following action plan:

Replacement of SEM at Agia, Mirza(Azara), Salakati : Replacement rescheduled on 26-27<sup>th</sup> September by Bongaigaon group. Assam requested installation at Mirza by 30<sup>th</sup>. Sept after Durga Puja.

**NERTS may intimate status of installation so far.**

**4. Time Drift in Meters & action required:-**

All utilities were requested to carry out regular time correction and intimate status to NERLDC on regular basis.

**5. AMR scheme in NER.**

Status as per last meeting:

- i. NIT Issue : 18.09.2017
- ii. Bid Sell Up to : 17.10.2017
- iii. OBD : 23.10.2017
- iv. LOA : 25.11.2017

**NERTS may intimate status.**

**6. Testing of SEMs at accredited laboratory**

NERTS stated that fresh offer was received only from a single party viz. M/s Yadav Measurements Pvt. Limited. As per Offer of M/s YMPL, the estimated cost is Rs.12,55,500.00 excluding GST @18% plus boarding/lodging /local transportation extra.

NERTS intimated that no offer received from other parties. Metering Committee advised NERTS to wait for some more time.

**NERTS may update status.**

**7. Metering issues:**

- (i) Non-receipt of reading from Banduar (Udaipur)

**8. New SEMs in Bongaigaon NTPC:**

NTPC has submitted the schematic and it was decided that NERTS would hand over two SEMs to NTPC for start-up power of U-3 BgTPP.

**NERTS/NTPC may update status.**

**9. Providing 50 SEMs, 6 laptops and 6 DCDs to TSECL:**

NERTS stated the following:

GST invoice could not be generated. The system is generating error code during the process of invoice generation. Communicated to CC: Gurgaon for solution. Awaited solution.

**NERTS/NTPC may update status.**

**10. Meters at Manipur / Nagaland:**

Readings being sent regularly by Manipur and Nagaland.

**11. Supply of new 04 SEM for all lines:**

Supply of 04 Nos of SEM was allocated on priority bases to OTPC but Supply is still pending, Required Scheduled conformation as per 30th MM

It was agreed that NERTS would provide 4 SEMs to OTPC on priority. NERLDC clarified that these would be check meters to be connected in series with the existing SEMs in all outgoing EHV feeders in line with CEA Metering Regulations. For existing time drifted SEMs, OTPC was once again advised to provide time correction command to set-right meter time.

**OTPC may confirm.**

**Date and venue of next meeting.**