

**PROPOSED SHUTDOWN OF ELEMENTS FOR 115th OCCM- BAR CHART**

SN	Name of Element	November'2015					December'2015																															Time	Purpose
		26	27	28	29	30	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
<b>1. TRANSMISSION LINES</b>																																							
1	132KV Jiribam-Loktak-II																																				7:00 to 16:00 Hr	i) For Facilitating diversion of line on account of Railway Diversion Track construction. (ii) For shifting of vulnerable loc.222 affected by landslide	
2	132KV Dimapur-Imphal																																				7:00 to 16:00 Hr	Clearing of debris on account of landslide near loc.325-326	
3	132KV Dimapur-Doyang-I																																				7:00 to 16:00 Hr	CT Replacement in Y-Phase due to oil leakage	
4	400KV Bongaigaon-Azara TL																																				7:00 to 15:00 Hr	For clearing of trees in Rani Reserve Forest inclining towards line from either side & posing potential threat.	
5	400KV Bongaigaon-Byrnihat TL																																				7:00 to 15:00 Hr	For clearing of trees in Rani Reserve Forest inclining towards line from either side & posing potential threat.	
6	400KV Silchar-Azara TL																																				7:00 to 15:00 Hr	For clearing of trees in Rani Reserve Forest inclining towards line from either side & posing potential threat.	
7	400KV Misa-Balipara-I																																				7:00 to 15:00 Hr	For trip circuit connection & enabling trip operation in connection with NTAMC project	
8	400KV Misa-Balipara-II																																				7:00 to 15:00 Hr	For trip circuit connection & enabling trip operation in connection with NTAMC project	
9	400KV Balipara-Biswanath Chariali-I along with 50MVAR Line Reactor																																				7:00 to 15:00 Hr	Checking/enabling of remote operation of Isolators along with alignment correction for facilitating implementation of NTAMC project	
10	400KV Balipara-Biswanath Chariali-II along with 50MVAR Line Reactor																																				7:00 to 15:00 Hr	Checking/enabling of remote operation of Isolators along with alignment correction for facilitating implementation of NTAMC project	
11	400KV Balipara-Bongaigaon-I																																				7:00 to 15:00 Hr	For trip circuit connection & enabling trip operation in connection with NTAMC project	
12	132KV Salakati-Gelephug TL																																				7:00 to 15:00 Hr	For Annual Maintenance Program	
13	132KV Salakati-Gelephug TL																																				7:00 to 15:00 Hr	Rectification of main CB & Line Isolator	
14	132KV Ranganadi-Lekhi TL																																				7:00 to 15:00 Hr	For tightening of jumpers where hotspots have been found on account of high continuous loading	
15	132KV Jiribam-Haflong TL																																				7:00 to 15:00 Hr	For clearing of debris deposited as a result of earth work carried out in connection with Railway Track Gauge conversion ( loc.75-78)	
16	132KV Jiribam-Aizawl TL																																				7:00 to 15:00 Hr	For clearing of trees leaning towards line from uphill side from 148 to 233, 388-392	
17	400KV D/C Pallatana-Surajmani Nagar TL																																				7:00 to 15:00 Hr	For facilitating stringing of 400KV SurajmaniNagar-Comilla(Indo-Bangla) TL at power Line TL	
18	132KV Aizawl-Zemabawk-II																																				7:00 to 15:00 Hr	For Annual Maintenance Program	
19	132KV Khandong-Khliehriat-I																																				7:00 to 15:00 Hr	Replacement of insulators damaged during heavy lightning at loc.70A & 71 B	
<b>2. SUBSTATION</b>																																							
<b>400/220KV Balipara Substation</b>																																							
1	400/220KV ICT Main Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program. ICT remains in service	
2	400/220KV ICT & Bus Reactor-I Tie Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program. No outage	
3	400KV Misa-II Main Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program.	
4	400KV Bongaigaon-I-Biswanath Chariali-III Tie Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program.	
5	400KV Biswanath Chariali-I Main Bay																																				7:00 to 15:00 Hr	Checking/enabling of remote operation of Isolators along with alignment correction for facilitating implementation of NTAMC project	
6	400KV Biswanath Chariali-I Tie Bay																																				7:00 to 15:00 Hr	Checking/enabling of remote operation of Isolators along with alignment correction for facilitating implementation of NTAMC project	
7	50MVAR Bus Reactor-I Main Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program. Reactor remains in service	
8	400KV Biswanath Chariali-II Tie Bay																																				7:00 to 15:00 Hr	Checking/enabling of remote operation of Isolators along with alignment correction for facilitating implementation of NTAMC project	
9	220KV Samaguri Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program.Feeders remains in service thro' Tie Bay	
10	400KV Biswanath Chariali-II Main Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program.Feeders remains in service thro' Tie Bay	
<b>400/220KV Bongaigaon Substation</b>																																							
1	80MVAR Bus Reactor-III Main Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program. Reactor remains in service	
2	50MVAR Bus Reactor-II Main Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program. Reactor remains in service	
3	400KV Balipara-I Main Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program. Feeder remains in service	
4	400KV Balipara-IV Main Bay																																				7:00 to 15:00 Hr	Annual Maintenance Program. Feeder remains in service	
<b>400kV Silchar SS</b>																																							
1	63MVAR Bus Reactor-II																																				10:00 to 12:00 Hr	For refitting of corona rings	
<b>132KV Ziro Substation</b>																																							
1	132/33KV ICT																																				7:00 to 15:00 Hr	Annual Maintenance Program.	

NHPC																																
1	Loktak Unit-3	← For Continuous Shutdown →																												Continuous S/D from 01.12.15(00:00 Hrs) to 30.12.15	Annual Maintenance Purpose	
AEGCL																																
1	132kv Lines LTPS Mariani S/C																														08:00 to 16:00 Hrs	Corridor cleaning, Jumper checking
2	132kv Srikona-Pailapool line																													09:00 to 16:00 Hrs	Line maintenance works at Kalabil area	
3	132kv Silchar(PGCIL) - DLCR line																													Cont. S/D from 27.11.15(10:00 hr) to 28.11.15 (15:00hr)	Re-arrangement of 132KV Bus connection & charging of Hallakandi New GSS	
4	132kv Srikona-Pailapool line																													09:00 to 16:00 Hrs	Line maintenance works at Labok area	
5	132kv Panchgram - LMSG line																													09:00 to 16:00 Hrs	Line maintenance works	
6	220kv Namrup - Tinsukia feeder no 1 & 2																													08:00 to 16:00 Hrs	Preventive maintenance of EHV lines	
7	132kv Tinsukia - NTPS S/C line																													08:00 to 16:00 Hrs	Preventive maintenance of EHV lines	
8	220kv Mirza-Sarusajai line 1																													08:00 to 11:00 Hrs	Annual Maintenance purpose	
9	220kv Mirza-Sarusajai line 2																													12:00 to 15:00 Hrs	Annual Maintenance purpose	
10	220kv Mirza-Boko line																													10:00 to 15:00 Hrs	Annual Maintenance purpose	
NEEPCO																																
1	132KV Balipara Khupi Kimi Transmission line																													Daily shutdown (07:00 to 16:00hrs)	Ground clearance & Jungle clearance works	

Note:  For Continuous Shutdown  
 For Daily Shutdown