

N FOR 153rd OCC MEETING

SN	Name of Element	#	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	Time	Remarks	Category																							
TRANSMISSION LINES																																														
132kV Transmission lines																																														
1	132kV Aizawl-kumarghat TL																					Cont. SD 08:00(13.03.19) to 16:00 Hrs(18.03.19)	For facilitating Erection and Stringing of terminal tower loc no. 21 and 25B in connection with Railway Diversion work between loc.20 to loc.26	New Construction Related Shut Down																						
2	132kV Aizawl-kolasib TL																					08:00 to 15:00 Hrs	For sag adjustment of R-phase conductor at loc no. 125-126 for enhanced clearance (line is almost 20 years old).	Existing System Improvement Related Shut Down																						
3	132kV Balipara - Khupi TL (AP consent Required)																					1000hrs to 1400hrs	CT tan delta and line bay maintenance	Existing System Normal Maintenance Related Shut Down																						
4	132kV S/C Jaima-Gauripur T/L (AEGCL)																					09:00 to 15:00 Hrs	Stringing activities at Loc. No. 134/0-135/0 & 127/0-128/0 in respect of 400KV D/C (Quad) Jigmeling-Alipurduar T/L over crossing of 132kV S/C Jaima-Gauripur T/L (AEGCL) near Srirampur .. Assam	New Construction Related Shut Down																						
5	132kV Haflong- Umrangsoo feeder																					08:00hrs to 16:00hrs	Jumper changing is to be done at location no:35,36 and 43 of said feeder	Existing System Normal Maintenance Related Shut Down																						
6	132kV -Melriat-Zemabawk TL																					07:00 to 15:00 Hrs	for AMP of bay equipments and infringement clearance of Loc. 15-18	Existing System Normal Maintenance Related Shut Down																						
7	132kV Haflong-Haflong(ASEB)																					08:00hrs to 16:00hrs	AMP bay maintenance activities	Existing System Normal Maintenance Related Shut Down																						
8	132kV Khehriat - Khandong 1																					08:00hrs to 16:00hrs	AMP bay maintenance activities	Existing System Normal Maintenance Related Shut Down																						
9	132 KV Kopili - Khandong #1 TL																					Cont. SD 08:00 to 15:00 Hrs	Dismantling of existing Bay equipment's for integrate through GIS. 132 KV Khandong #1 Line will be out of service till commissioning of GIS Kopili SS. Dismantling of Bus CVT-II at Kopili SS for GIS Duct foundation.	New Construction Related Shut Down																						
10	132kV Aizawl Zemabawk 1 TL																					08:00hrs to 16:00hrs	for commissioning of new distance Protection relay.	Existing System Improvement Related Shut Down																						
11	132kV Silchar - Srikona # 1 TL																					08:00hrs to 16:00hrs	AMP of Bay equipments	Existing System Normal Maintenance Related Shut Down																						
12	132 KV Badarpur - Kumarghat TL																					07:00 to 15:00 Hrs	AMP of Bay equipments and for repairing of conductor at Loc no-82-83.	Existing System Normal Maintenance Related Shut Down																						
13	132 KV Jiribam-Tipaimukh TL																					08:00hrs to 16:00hrs	AMP of Switchyard Bay equipments and TL	Existing System Normal Maintenance Related Shut Down																						
220kV Transmission lines																																														
14	220kV Balipara - Sonabil TL (Assam consent Required)																					0900hrs to 1500hrs	Excess jumper cutting in L.A. Line bay Maintenance. Attending of hotspots in the line bay.	Existing System Normal Maintenance Related Shut Down																						
15	220 KV Misa-Old Mariani TL																					08:00hrs to 16:00hrs	Z28 89A Alignment & AL pipe Connection	New Construction Related Shut Down																						
16	220 KV Misa-New Mariani TL																					08:00hrs to 16:00hrs	Isolator Alignment & AL pipe Connection	New Construction Related Shut Down																						
17	220 KV Misa-Old Mariani TL																					08:00hrs to 16:00hrs	400 KV HTLS stringing for main bus & Old Mariani line diversion related bus work.	New Construction Related Shut Down																						
18	220 KV Misa - Samaguri # 1 TL																					08:00hrs to 16:00hrs	Replacement of old CT Junction Bow with new one for Augmentation of New Busbar protection panel	New Construction Related Shut Down																						
19	220 KV Misa - Samaguri # 2 TL																					08:00hrs to 16:00hrs	Replacement of old CT Junction Bow with new one for Augmentation of New Busbar protection panel	New Construction Related Shut Down																						
20	220 KV Misa - Kopili # 1 TL																					08:00hrs to 16:00hrs	Replacement of old CT Junction Bow with new one for Augmentation of New Busbar protection panel	New Construction Related Shut Down																						
21	220 KV Misa - Kopili # 2 TL																					08:00hrs to 16:00hrs	Replacement of old CT Junction Bow with new one for Augmentation of New Busbar protection panel	New Construction Related Shut Down																						
22	220 KV Misa - Dimapur #1 TL																					08:00hrs to 16:00hrs	Replacement of old CT Junction Bow with new one for Augmentation of New Busbar protection panel	New Construction Related Shut Down																						
23	220 KV Misa - Dimapur # 2 TL																					08:00hrs to 16:00hrs	Replacement of old CT Junction Bow with new one for Augmentation of New Busbar protection panel	New Construction Related Shut Down																						
24	220 KV Alipurduar - Salakati - 1																					08:00hrs to 16:00hrs	Installation of Transmission Line arrester in the proposed line by POWERGRID Eastern Region.	Existing System Improvement Related Shut Down																						
25	220 KV Alipurduar - Salakati - 2																					08:00hrs to 16:00hrs		Existing System Improvement Related Shut Down																						
400kV Transmission lines																																														
26	400 KV Binaguri Bongaigaon Ckt-1																					Cont. SD 08:00 to 16:00 Hrs	For Destrining and stringing of damaged conductors at various spans along with repair works due to conductor theft by microarsts. Approved in ERPC OCCM forum, discussed with NLDC.	Existing System Improvement Related Shut Down																						
27	400 KV Binaguri Bongaigaon Ckt-2																					Cont. SD 08:00 to 16:00 Hrs	For Destrining and stringing of damaged conductors at various spans along with repair works due to conductor theft by microarsts. Approved in ERPC OCCM forum, discussed with NLDC.	Existing System Improvement Related Shut Down																						
28	400 KV Misa - Balipara Ckt#1 TL																					08:00hrs to 16:00hrs	Working clearance required for installation of Isolator of ICT 3 at Misa	New Construction Related Shut Down																						
29	400 KV Misa - Balipara Ckt#2 TL																					08:00hrs to 16:00hrs	Working clearance required for installation of Isolator of ICT 3 at Misa	New Construction Related Shut Down																						
30	400kV Bongaigaon - Azara TL																					07:00 to 15:00 Hrs	For facilitating connections of dropper/jumpers of related to restoration of failed line reactor.	Existing System Normal Maintenance Related Shut Down																						
800kV Transmission lines																																														
33	800 KV HVDC Biswanath Chariali -Agra Pole-1																					07:00 to 15:00 Hrs	Erection of new tower at loc.118 on Pile foundation. Existing tower 118 is required to be shifted on Pile following erosion by river Mansiri. OCC Meeting w.e.f 31.01.19 to 09.02.19 under the category " Existing System Improvement Related Shut	Existing System Improvement Related Shut Down																						
400 kV Silchar SS																																														
34	400 kV Azara Main Bay																					08:00hrs to 16:00hrs	AMP of Bay equipment.	Existing System Normal Maintenance Related Shut Down																						
35	400 kV ICT-2 Main Bay																					08:00hrs to 16:00hrs	AMP of bay equipments, No. outage of equipment.	Existing System Normal Maintenance Related Shut Down																						
36	400 kV Bus Reactor-2 Main Bay																					08:00hrs to 16:00hrs	AMP of bay equipments, No. outage of equipment.	Existing System Normal Maintenance Related Shut Down																						
37	400 kV Palatana 1 Main Bay																					08:00hrs to 16:00hrs	AMP of bay equipments, No. outage of equipment.	Existing System Normal Maintenance Related Shut Down																						
800kV HVDC BNC SS																																														
38	80MVAR Bus Reactor- 1																					08:00hrs to 16:00hrs	AMP of BR with Bay equipment.	Existing System Normal Maintenance Related Shut Down																						
39	80MVAR Bus Reactor- 2																					08:00hrs to 16:00hrs	AMP of BR with Bay equipment.	Existing System Normal Maintenance Related Shut Down																						
40	400kV 200MVA ICT 1																					08:00hrs to 16:00hrs	AMP of ICT with Bay equipment.	Existing System Normal Maintenance Related Shut Down																						
41	400kV 200MVA ICT 2																					08:00hrs to 16:00hrs	AMP of ICT with Bay equipment.	Existing System Normal Maintenance Related Shut Down																						
42	400kV ICT 1 & ICT 2 Tie bay																					08:00hrs to 16:00hrs	AMP of Bay equipment , no outage of element	Existing System Normal Maintenance Related Shut Down																						
43	400kV Bus Reactor 1 tie bay																					08:00hrs to 16:00hrs	AMP of Bay equipment , no outage of element	Existing System Normal Maintenance Related Shut Down																						
44	400kV Bus Reactor 2 tie bay																					08:00hrs to 16:00hrs	AMP of Bay equipment , no outage of element	Existing System Normal Maintenance Related Shut Down																						
220 kV Kopili PH (NEEPCO)																																														
45	220 KV Bus-A & B at Kopili SS																					08:00hrs to 16:00hrs	Dismantling of old Isolator & Erection of new Isolator at newly commissioned 160 MVA ICT at Kopili. Affected Feeders: 1)220 KV Bus-A & B at Kopili SS. 2)220 KV Kopili-Misa ckt I,II&III line 3) All Generating Bays.	New Construction Related Shut Down																						
46	132 KV Bus CVT-II at Kopili SS																					08:00hrs to 16:00hrs	Dismantling of Bus CVT for GIS Duct foundation.	New Construction Related Shut Down																						
400 kV Misa SS																																														
47	220 KV Bus -A																					08:00hrs to 16:00hrs	220 KV high level Isolator Erection balance work & Alignment	New Construction Related Shut Down																						
48	220 KV Bus -B																					08:00hrs to 16:00hrs	Z28 89B Alignment & AL pipe Connection	New Construction Related Shut Down																						
49	33 KV Tertiary Reactor 04 nos (25 MVAR x 4 = 100MVAR)																					Cont. SD 08:00 to 16:00 Hrs	For new connection with new 500MVA ICT-1 .04 nos. 33 KV Tertiary Reactor will be out of service.	New Construction Related Shut Down																						
50	400/220kV 15MVA ICT-1 (105x3Ph)																					Cont. SD 08:00 to 16:00 Hrs	For replacement of 315MVA ICT-I(105x3Ph TELK) with 500MVA ICT (TBEA)	New Construction Related Shut Down																						
51	400/220kV 315MVA ICT-II																							For connection of Auxiliary supply from LV side of 315 MVA ICT-II to incomer bay.	New Construction Related Shut Down																					

