SHUTDOWN REQUISITION FOR 136th OCC

SN	Name of Element	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	Time	Remarks
1.TRANSMISSION LINES																																				
132kV Transmission lines																																				
1	132kV Aizawl-Kumarghat TL																																		08:00 to 16:00	For installation of Transmisison Line LA (Rescheduled , already approved in 135th OCCM)
2	132kV Agartala- Agartala Ckt- I																																		08:00 to 16:00	for jumper tightening and bay maintenance
3	132kV Agartala- Agartala Ckt- II																																		08:00 to 16:00	for jumper tightening and bay maintenance
4	132kV Badarpur - kolasib TL																																		08:00 to 16:00	Railway diversion work at location 286 to 290.
5	132KV Silchar - Badarpur # 1 TL																																		08:00 to 16:00	Earth cutt ing in bet. Tower loc. no 62-63 for enhancing ground clearance for ensuring safety of commutators
6	132kV Badarpur- Panchgram TL																																		08:00 to 16:00	CT tan delta , timing & DCRM of CB at Panchgram end
220kV Transmission lines																																				
7	220kV Balipara - Sonabil TL																																		09:00 to 15:00	Replacement of damaged conductor B ph line side of line Iso. , Annual Maintenance of Bay Equipments
8	220kV Misa - Samaguri # 1 TL																																		08:00 to 16:00	Annual maintenance activites of bay equipments.
9	220kV Misa - Samaguri # 2 TL																																		08:00 to 16:00	Annual maintenance activites of bay equipments.
10	220kV Misa - kopili # 1 TL																																		08:00 to 16:00	S/D for re-tension of conductors between Loc.No.197- 205 for enhancing ground clearance for ensuring safety of commutators (New roads constructed under line)
11	220kV Misa - kopili # 2 TL																																		08:00 to 16:00	S/D for re-tension of conductors between Loc.No.197- 205 for enhancing ground clearance for ensuring safety of commutators(New roads constructed under line)
400kV Transmission lines																																				
12	400 kV Bongaigaon-NSLG # 2																																		10:00 to 12:00	AMP of Line equipments and LR
13	400 kV Bongaigaon-NSLG # 1																																		10:00 to 12:00	For AMP of Line Reactor and Line equipments (already approved in 135th OCCM)
14	400kV Balipara - Bongaigaon # 1 TL along with LR																																		09:00 to 13:00	Rectification of main and tie bay line side isolators which are in stuck condition. (LR shall be out of service)
400KV BONGAIGAON S/S																																				
15	400kV New Siliguri # 1 Main Bay																																		09:00 to 15:00	Annual Maintenance of Bay Equipments , no outage of equpments.(already approved in 135th OCCM)
16	400kV Balipara # 1 Main Bay																																		09:00 to 15:00	Annual Maintenance of Bay Equipments , no outage of equpments.(already approved in 135th OCCM)
17	50 MVAR Bus Reactor 2																																		07:00 to 11:00	Annual Maintenance work , BR will be out of service (already approved in 135th OCCM)
18	400 kV Azara Main Bay																																		09:00 to 15:00	Annual Maintenance of Bay Equipments , no outage of equpments.(already approved in 135th OCCM)
19	400 kV Byrnihat Main Bay																																		09:00 to 15:00	Annual Maintenance of Bay Equipments , no outage of equpments.(already approved in 135th OCCM)
20	400 kV Bus Reactor # 1 Main Bay																																		07:00 to 11:00	Annual Maintenance of Bay Equipments , no outage of equpments.
21	400 kV Azara LR																																		Continuous SD	For replacement of 03 nos. HV Bushing , LR shall out of service
22	400 kV Balipara # 1 LR																																		08:00 to 16:00	NGR by-pass works, LR shall out of service
23	400 kV Balipara # 2 LR																																		08:00 to 16:00	NGR by-pass works, LR shall out of service
24	400 kV Byrnihat LR																																		08:00 to 10:00	AMP of LR, LR shall out of service
25	400 kV Byrnihat Main Bay																																		07:00 to 11:00	Annual Maintenance of Bay Equipments , no outage of equpments.
26	400 kV Byrnihat Tie Bay																																		07:00 to 11:00	Annual Maintenance of Bay Equipments , no outage of equpments.
27	400 kV Alipurduar # 2 Main Bay																																		07:00 to 11:00	Annual Maintenance of Bay Equipments , no outage of equpments.
400kV BALIPARA SS																																				
28	Bongaigaon # 2 & BNC # 4 Tie Bay																																		08:00 to 16:00	Annual Maintenance of Bay Equipments
29	Bongaigaon # 3 reactor																																		09:00 to 12:00	For testing of NGR bypass scheme , LR shall be out of service.
30	Bongaigaon # 4 reactor																																		09:00 to 12:00	For testing of NGR bypass scheme , LR shall be out of service.
400KV Misa Substation																																				
31	220kV Bus Coupler Bay																																		08:00 to 16:00	Annual Maintenance of Bay Equipments
220KV Salakati Substation																																				
32	220/132 kV ICT# 1																																		10:00 to 15:00	Annual Maintenance of ICT
33	220 kV Alipurduar # 2																																		10:00 to 16:00	Annual Maintenance of Bay Equipments. Line shall remain charged.
132kV Imphal Substation																																				
34	20 MVAR 132KV Bus Reactor																																		08:00 to 16:00	For hot oil circulation required for enhancement of life of reactor , subject to weather condition at Imphal. (already approved in 135th OCCM)
132kV Jiribam Substation																																				
35	132/33 6.3 MVA Transformer (Manipur)																																		09:00 to 15:00	AMP Activities o f HV SIDE BAY EQUIPMENT
Assam																																				
36	220kV Mirza-Agia																																		09:00 to 16:00	Pre-Puja Maintenance
37	400/220kV, 315 MVA Transfomer -2 at Mirza																																		08:00 to 16:00	Routine maintenance
38	132kv BUS at Panchgram																																		09:30 to 15:30	Pre-Puja Maintenance
39	400KV Azara-Silchar Line																																		08:00 to 16:00	Routine maintenance
40	315MVA, 400/220KV ICT-1																																		08:00 to 16:00	Routine maintenance
41	315MVA, 400/220KV ICT-2																																		08:00 to 16:00	Routine maintenance
42	132 KV Namrup-Bordubi S/C Line																																		08:00 to 16:00	For preventive maintenance of EHV lines
43	132 KV Tinsukia-Bordubi S/C line																																		08:00 to 16:00	For preventive maintenance of EHV lines
44	132KV and 33KV Main Bus/Bay																																		09:30 to 15:30	Pre Puja Maintenance works
45	132KV and 33KV Main Bus/Bay																																		09:30 to 15:30	Pre Puja Maintenance works
46	132Kv Srikona-Poilapool Line																																		09:00 to 16:00	Pre Puja Maintenance works
Tripura																																				
47	132 KV RC Nagar- Agartala line-I																																		08:00 to 15:00	Pre-Puja S/d
48	132 KV Dharmanagar – P K Bari																																		08:00 to 15:00	Pre-Puja S/d
49	132 KV RC Nagar- Agartala line-II																																		08:00 to 15:00	Pre-Puja S/d
50	132 KV Kumarghat – P K Bari																																		08:00 to 15:00	Pre-Puja S/d
51	132kV PKBari Main Bus																																		08:00 to 15:00	Pre-Puja S/d
52	132 KV Dharmanagar- P K Bari																																		08:00 to 15:00	Pre-Puja S/d
OTPC																																				
53	132KV line(PLT-Suryamani Nagar)																																		08:00 to 15:00	replacement of bus dropper moose conductor
54	400KV Line-2(PLT-Silchar)																																		07:00 to 15:30	Lightning Arresters replacement of 63MVAR Line reactor
55	400KV Line-1(PLT-Silchar)																																		07:00 to 15:30	Lightning Arresters replacement of 63 MVAR Line reactor
56	ICT-1,125MVA																																		07:00 to 16:00	HV Side Lighting Arresters replacement of Transformer
MeECL																																				
57	132kV Umtru - Kahelipara D/C																																		10:00 to 13:00	Jungle Clearing
58	220kV Misa-Killing D/C																																		09:00 to 16:00	Jungle Clearing
	Continuous S/D																																		Daytime S/D	