

SN	Name of Element	PROPOSED SHUTDOWN FOR 148th OCC MEETING														Time	Remarks	Category																				
		14	15	16	17	18	19	20	21	22	23	24	25	26	27				28	29	30	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
TRANSMISSION LINES																																						
132kV Transmission lines																																						
1	132kV Aizawl-Kolasib T/L																																			08:00 to 16:00 HRS	Infringement clearing at Loc. No 147, 131, 124	Existing System Normal Maintenance Related Shut Down
2	132kV Aizawl- Tipaimukh T/L																																			08:00 to 16:00 HRS	Infringement clearing at Loc. No. 372,373,374, 376, 377,378,379,380	Existing System Normal Maintenance Related Shut Down
3	132kV Badarpur-Kolasib bay																																			08:00 to 16:00 HRS	For replacement of CT MB at Badarpur S/S and infringing clearance in TL	Existing System Improvement Related Shut Down
4	132kV Aizawl-Kumarghat T/L																																			Cont. SD 08:00 to 16:00 Hrs	Railway diversion work at Sarang involving tower erection and stringing work for loc no. 21 & 70.	Existing System Improvement Related Shut Down
5	132kV Tipaimukh - Jiribam T/L																																			08:00 to 16:00 HRS	Installation of Tr. Line Arrestors at identified locations (S/D approved in 147th OCCM)	Existing System Normal Maintenance Related Shut Down
6	132kV Badarpur-Jiribam bay T/L																																			Cont. SD 08:00 to 16:00 Hrs	Stringing of 400 KV Silchar - Melriat T/L (Section AP 1/0 to AP 1A/0)	New Construction Related Shut Down
7	132kV Badarpur-Kumarghat T/L																																			08:00 to 16:00 HRS	For infringing clearing in TL	Existing System Normal Maintenance Related Shut Down
8	132kV Badarpur-Khelrihat T/L																																			08:00 to 16:00 HRS	For infringing clearing in TL	Existing System Normal Maintenance Related Shut Down
9	132kV D.C Silchar-P.K Bari # 1																																			08:00 to 16:00 HRS	For removing roller & infringing clearing in TL	Existing System Normal Maintenance Related Shut Down
10	132kV D.C Silchar-P.K Bari # 2																																			08:00 to 16:00 HRS	For removing roller & infringing clearing in TL	Existing System Normal Maintenance Related Shut Down
11	132kV Jiribam-Tipaimukh T/L																																			08:00 to 16:00 HRS	infringement clearance between location number 173 to 218	Existing System Normal Maintenance Related Shut Down
12	132 kV Kumarghat - RC Nagar T/L																																			08:00 to 16:00 HRS	infringement clearance of the line at various locations	Existing System Normal Maintenance Related Shut Down
13	132 KV DC Silchar-Hailkandi T/L along with S/D of 132KV S/C Panchgram-Serospour (AGCIL)																																			08:00 to 16:00 HRS	Rectification of cross Arm at location no 107 to 108 . Work shall involve Stringing & destringing of conductor of 132KV S/C Panchgram-Serospour (AGCIL)	Existing System Normal Maintenance Related Shut Down
220kV Transmission lines																																						
14	220 KV Salakati -BTPS#1																																			09:00hrs to 16:00hrs	Replacement of Defective CVT	Existing System Normal Maintenance Related Shut Down
15	220KV Misa-Old Mariani T/L																																			09:00hrs to 16:00hrs	erection work under NERSS - IV construction project	New Construction Related Shut Down
16	220 kV Misa- Kopili 3 T/L																																			09:00hrs to 16:00hrs	AMP of bay equipments.	Existing System Normal Maintenance Related Shut Down
17	220 kV Misa - Kopili #2																																			08:00 to 16:00 Hrs	Replacement of existing Telk Make CB(more than 25yrs age) with new Seimens breakers) , work shall involve Retrofitting of CB,dismantling,erection and testing works. From 04th Sep to 07th Sep , 220 kV Misa- Kopili#2 shall remain charged via Bus Coupler, hence BUS-A at Misa shall operate as Transfer Bus.	Existing System Improvement Related Shut Down.
400kV Transmission lines																																						
18	400KV D.C Silchar-PALLATANA #2																																			08:00 to 16:00 HRS	For infringing clearing in TL	Existing System Normal Maintenance Related Shut Down
19	400KV Bongaigaon - Azara ckt with Line Reactor																																			09:00 hrs to 16:00 hrs	AMP of Reactor. Line shall be out of service	Existing System Normal Maintenance Related Shut Down
20	400KV Bongaigaon -Balipara ckt 4 with Line Reactor																																			09:00 hrs to 16:00 hrs	AMP of Reactor. Line shall be out of service	Existing System Normal Maintenance Related Shut Down
21	400KV Bongaigaon -Balipara ckt 3 with Line Reactor																																			09:00hrs to 16:00 hrs	AMP of Reactor. Line shall be out of service	Existing System Normal Maintenance Related Shut Down
22	400KV Bongaigaon -Barnhat with Line Reactor																																			09:00hrs to 16:00 hrs	AMP of Reactor. Line shall be out of service	Existing System Normal Maintenance Related Shut Down
800 kV HVDC Biswanath Chariali																																						
23	800 kV HVDC Biswanath Chariali -Agra Pole-1																																			08:00 to 16:00 Hrs	Erection of new tower at loc.118 on Pile foundation. Existing tower 118 is required to be shifted	New Construction Related Shut Down
220kV Samaguri Substation (ASSAM)																																						
24	220KV Misa - Samaguri #1 & 220KV Misa - Samaguri # 2 220KV Bus-2 at Samaguri Substation.																																			08:00 to 16:00 Hrs	Isolator replacement works of Bus - B isolator of Samaguri # 1 bay at Smaguri Substation. 220KV Bus-2 shall be out at Samaguri Substation. ** Rescheduled ,Shutdown to be approved after consent of AEGCL, Samaguri. (S/D approved in 147th OCCM)	Existing System Improvement Related Shut Down.
25	220KV Misa - Samaguri #1 & 220KV Misa - Samaguri # 2 220KV Bus-2 at Samaguri Substation.																																			08:00 to 16:00 Hrs	Isolator replacement works of Bus - B isolator of Samaguri # 2 bay at Smaguri Substation. 220KV Bus-2 shall be out at Samaguri Substation. ** Rescheduled ,Shutdown to be approved after consent of AEGCL, Samaguri. (S/D approved in 147th OCCM)	Existing System Improvement Related Shut Down.
220kV Misa Substation																																						
26	400 kV 50 MVAR Bus- Reactor																																			08:00 to 16:00 Hrs	Testing of B/R as per guidelines on completion of 25 years of service. Bus Reactor will be out of service.	Existing System Improvement Related Shut Down.
27	400 KV Balipara # Main-2 Bay																																			08:00 to 16:00 Hrs	AMP of bay equipments. No outage od element.	Existing System Normal Maintenance Related Shut Down
28	220kV Bus-B																																			08:00 to 16:00 Hrs	Pipe Bus erection work under NERSS - IV construction project (S/D approved in 147th OCCM)	New Construction Related Shut Down
400 kV Bongaigaon S/s																																						
29	400KV Bus #2																																			09:00 hrs to 17:00 hrs	Bus extension work under NERSS-III project. All feeders shall remain in service through	New Construction Related Shut Down
30	400KV Azara Main Bay																																			09:00 hrs to 16:00 hrs	Bay AMP, no outage of element	Existing System Normal Maintenance Related Shut Down
31	400KV Balipara ckt 4 Main Bay																																			09:00 hrs to 16:00 hrs	Bay AMP, no outage of element	Existing System Normal Maintenance Related Shut Down
32	400KV Balipara ckt 2 Main Bay																																			09:00 hrs to 16:00 hrs	Bay AMP, no outage of element	Existing System Normal Maintenance Related Shut Down
33	400KV Balipara ckt 1 Main Bay																																			09:00 hrs to 16:00 hrs	Bay AMP, no outage of element	Existing System Normal Maintenance Related Shut Down
34	400KV Alipurduar Ckt 2 Main Bay																																			09:00 hrs to 11:00 hrs	Bay AMP, no outage of element	Existing System Normal Maintenance Related Shut Down
35	400KV ICT 1 & NSLG 1 Tie Bay																																			09:00hrs to 16:00hrs	Bay AMP, no outage of element	Existing System Normal Maintenance Related Shut Down
36	400KV NSLG 1 Main Bay																																			09:00hrs to 16:00hrs	Bay AMP, no outage of element	Existing System Normal Maintenance Related Shut Down
37	400KV ICT 1 Main Bay																																			09:00hrs to 16:00hrs	Bay AMP, no outage of element	Existing System Normal Maintenance Related Shut Down
38	400KV Bus Reactor 1 Bay#09																																			09:00hrs to 16:00hrs	Bay AMP, no outage of element	Existing System Normal Maintenance Related Shut Down
39	400KV Byrnihat & JTPS 1 Tie Bay Bay#23																																			09:00hrs to 16:00hrs	Bay AMP, no outage of element	Existing System Normal Maintenance Related Shut Down
132 kV Kolasib Substation																																						
40	132kV Main Bus																																			10:00 to 14:00 Hrs	For replacement of rotating stool base of Bus Isolator in Aizawl bay	Existing System Normal Maintenance Related Shut Down
132 kV Badarpur Substation Substation																																						
41	132kV Main Bus																																			08:00 to 12:00 Hrs	For attending hot spot in Main bus dropper of Kolasib, Jiribam, Badarpur, Kumarghat & Silchar#1	Existing System Normal Maintenance Related Shut Down
400kV Balipara Substation																																						
42	5X105 MVA 400/220 kV ICT #1																																			08:00 to 16:00 hrs	Change over of ICT bank unit and testing of turreted CTs . ICT will be out of service	Existing System Normal Maintenance Related Shut Down
43	400KV BNC# 3 and Bong # 1 Tie bay																																			08:00 to 16:00 hrs	AMP related activities. No element outage	Existing System Normal Maintenance Related Shut Down
44	ICT#2 and B/R 2 tie bay																																			08:00 to 16:00 hrs	AMP related activities. No element outage	Existing System Normal Maintenance Related Shut Down
45	132kV Main Bus																																			08:00 to 16:00 hrs	Replacement of Bus Conductors with HTLS conductor under NERSS- III Scheme . Bus will be out of service. All 132 kV feeders will be out of service (Khupi and Sonabil) along with ICTs	New Construction Related Shut Down
46	50 MVAR B/R #1																																			08:00 to 16:00 hrs	Offline Drying out . Reactor will be out of service.	Existing System Normal Maintenance Related Shut Down
47	400kV Kameng # 1 and Bong# 4 Tie bay																																			08:00 to 16:00 Hrs	AMP of Bay Equipments . There shall be not outage of elements. (S/D approved in 147th OCCM)	Existing System Normal Maintenance Related Shut Down
ASSAM																																						
1	220KV Sarusajai- GIS line																																			09:00 to 15:00hrs	preventive maintenance	Existing System Normal Maintenance Related Shut Down
2	220KV Sarusajai- Sonapur line																																			09:00 to 15:00hrs	preventive maintenance	Existing System Normal Maintenance Related Shut Down
3	220KV Sarusajai- Mirza line I																																			08:00 to 17:00hrs	preventive maintenance	Existing System Normal Maintenance Related Shut Down
4	220KV Sarusajai- Mirza line II																																			08:00 to 17:00hrs	preventive maintenance	Existing System Normal Maintenance Related Shut Down
5	220KV																																					